




The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

Thomas S. Burack, Commissioner
January 26, 2010

DE 09-008
DE 08-024
DE 09-104
DE 08-051
DE 08-044



Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Re: Quarterly Emissions Verification Summary for Certified and Conditionally Certified Renewable Energy Sources

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities continue to meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Pinetree Power, Inc.
1241 Whitefield Rd
Bethlehem, NH 03574

Pinetree Power-Tamworth, Inc.
469 Plains Rd
Tamworth, NH 03886

Public Service Company of New Hampshire (PSNH) Schiller Station # 5
400 Gosling Rd
Portsmouth, NH 03801

Springfield Power, LLC
54 Fisher Corner Road
Springfield, NH 03284

DES recommends continued conditional certification of the following wood-fired power plant as a renewable energy source, because DES anticipates that the facility will eventually meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for TSP and NOx, respectively:

Indeck
151 Smith River Road
Alexandria, NH 03222

If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely

Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Maureen Reno, NH PUC