

Raulerson & Middleton Professional Association

900 Elm Street, P.O. Box 326 | Manchester, NH 03105-0326 Tel: 603.625.6464 | Fax: 603.625.5650 | www.mclane.com MANCHESTER CONCORD PORTSMOUTH WOBURN MA

JINJUE PAK Direct Dial: (603) 628-1250 Email: jinjue.pak@mclane.com Licensed in MA, NH and NY

October 5, 2011

Via Electronic Mail and Hand Delivery

Ms. Debra A. Howland Executive Director and Secretary New Hampshire Public Utilities Commission 21 S. Fruit Street, Suite 10 Concord, NH 03301

Re: Docket No. DE 10-020: Granite State Electric Company d/b/a National Grid Default Service Rates; Seventh Loss Factor Report

Dear Ms. Howland:

On March 22, 2010, the Commission issued Order No. 25,083 approving Granite State Electric Company d/b/a National Grid's ("National Grid") default service rates. In that order, the Commission required that the Company submit a report by March 31, 2010 and every quarter thereafter until its Tewksbury meter is replaced providing certain information regarding the Tewksbury meter replacement. The purpose of this letter is to provide the Commission with the seventh such report.

For the period June 23, 2011 through September 30, 2011, the only edits to the meter measurements were made on August 2, 2011. The readings for hours 15 and 16 on August 2, 2011 were determined to be faulty and required editing. It was observed that the primary Tewksbury meter measurements deviated from alternate data point measurements by significant amounts. The faulty data was revised using the best available data from a reliable alternative source. Based on the most current engineering estimates, the project is on track toward completion by the end of this year.

Ms. Debra A. Howland October 5, 2011 Page 2

The Company will continue to provide these quarterly reports until the Tewksbury meter is replaced. Should you have any questions regarding this matter, please do not hesitate to contact me.

Sincerely,

Jinjue Pak

cc: Service List (via electronic mail) Celia O'Brien, Esq.