



Spanmaster ® Release 3.1 Sag / Tension Computations 09/01/11 Waveguide

Waveguide River and Rail Crossings

					E*A LOAD	MAX.
X-SECT	EFF	NOMINAL	EFF.EXP.	CABLE	BEARING	RATED
AREA	MODULUS	DIAM	COEFF.	WEIGHT	CAPACITY	LOAD
(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	65′
		1.108		0.3170		
	AREA (sq.in) 0.0352	AREA MODULUS (sq.in) (psi) 0.0352 2.60E+07	AREA MODULUS DIAM (sq.in) (psi) (in) 0.0352 2.60E+07 0.5782 2.70E+05 0.858	AREA MODULUS DIAM COEFF. (sq.in) (psi) (in) (1/Γ) 0.0352 2.60E+07 0.250 5.60E-06 0.5782 2.70E+05 0.858 1.13E-05	AREA MODULUS DIAM COEFF. WEIGHT ((sq.in) (psi) (in) (1/F) (1/F) ((b/ft) 0.0352 2.60E+07 0.250 5.60E-06 0.1210 0.5782 2.70E+05 0.858 1.13E-05 0.1960	X-SECT AREA EFF MODILUS NOMINAL DIAM (in) EFF.EXP. COEFF. (if/F) CABLE WEIGHT (lb/f) BEARING CAPACITY (lb/f) 0.0352 2.60E+07 0.250 5.60E-06 0.1210 914940 0.5782 2.70E+05 0.858 1.13E-05 0.1960 155982


NESC RESULTS

Loading Condition	Temp.	Ice Load lb/ft	Ice Thick in	Wind Constant lb/ft	Wind Load lb/sq ft	Load + Const	Sag	Tension	Chg From Input Conditions	Point 69	Sag	Sag	Vector Angle Deg
Rule 251 - Heavy	0.0		.50	.3	4.0	1.793	2.69	1585	0.07	2.69	1.27	2.37	
232A1	120.0	0.000	.00	.0	0.0	0.317	1.74	434	0.02	1.74	0.00	1.74	0.0

Span Length = 138.00 ft Span Sag = 1.38 ft (16.6 in) Span Tension = 547 lb Max Load = 6,650 lb Usable load (60%) = 3,990 lb Catenary Length = 138.037 ft Stress Free Length @ Installed Temperature = 137.954 ft

Unloaded Strand Sag = .76 ft (9.2 in) 0.55 % Tension = 377 lb

Midspan % Length Clearance (F) Sag (ft) N/A N/A N/A N/A -40.0 .80 .83 .88 .92 .97 1.02 1.07 1.13 1.25 1.31 1.35 1.45 1.52 1.59 1.67 1.74 903 861 820 780 -0.02 -0.02 -0.01 -0.01 -30.0 -20.0 -10.0 .0 10.0 20.0 30.0 40.0 50.0 60.0 70.0 80.0 90.0 110.0 120.0 130.0 -0.01 -0.01 -0.01 -0.01 0.00 N/A N/A N/A N/A N/A 742 705 669 636 604 574 546 520 496 474 0.00 0.00 0.00 0.01 0.01 N/A N/A N/A N/A N/A 453 434 416 N/A N/A N/A N/A 0.01 0.02 0.02 0.02



E-232/2 - T-90/14(Existing joint owned utility pole (PSNH/Fairpoint) in existing Right-of-Way)

E-232/2 - T-90/14

E-23/12 - T-90/12(Existing joint owned utility pole (PSNH/Fairpoint) in existing Right-of-Way)

Project # TID-138 - Primary 7

Proposed River Crossing Lancaster, NH

New Hampshire Optical Systems, Inc.

Proposed

River Crossing

Lancaster, NH

The heights of structures shown hereon are

Nikon 362 total station during a site survey or

The horizontal distance between the nearest

bridge edge and the existing overhead wires

Because of the close horizontal proximity to

the existing bridge structure, the simplified drawing is submitted with vertical distances

measured to the structure. This process simplifies the preparation and review of the

The smallest vertical distance from the top of existing bridge deck to the lowest existing

crossing without jeopardizing its intent to

protect the safe usage of the waterway

The vertical distance between the top of water and bridge deck is approximately 18'.

Vertical distances are representative of

attachment heights after utility make ready

ranges from 5' to 8'.

overhead wires is 16'.

moves are completed.

99 Pine Hill Rd. Nashua, NH 03063

(603-821-6467)

Notes:

Mechanic St., Lancaster, NH Nearest cross street- Pleasant St

Sheet 2 of 2


Construction Notes: NHOS proposes to install a ¼ inch metal supporting

strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole



E-23/12 - T-90/12

 $K: \Pr_x \subseteq USNH\dwgs\Lancaster_river_xing = 138 \cdot 138$







Spanmaster ® Release 3.1 Sag / Tension Computations


	X-SECT ARFA	EFF MODULUS	NOMINAL DIAM	EFF.EXP.	CABLE WEIGHT	E*A LOAD BEARING CAPACITY	MAX. RATED LOAD
Selected Cables	(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
ORF-O-288-LN	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	651
5/16"11.2mEHS	0.0595	2.60E+07	0.313	5.60E-06	0.2050	1545960	11200

Waveguide River and Rail Crossings

NESC RESULTS

					Horz	Result			% Len	Sag @	Horz	Vert	
Loading		Ice	Ice	Wind	Wind	Load	Sag	Tension	Chg From	Point	Sag	Sag	Vector
Condition	Temp.	Load	Thick	Constant	Load	+ Const	-		Input	178.5	Comp	Comp	Angle
	(F)	lb/ft	în	lb/ft	lb/sq ft	lb/ft	ft	lb	Conditions	ft	ft	ft	Deg
Rule 251 - Heavy	0.0	1.039	.50	.3	4.0	1.912	7.75	3919	0.10	7.77	3.48	6.93	26.7
232A1	120.0	0.000	.00	.0	0.0	0.401	4.21	1516	0.01	4.22	0.00	4.21	0.0

Span Length = 357.00 ft	Temp	Midspan	Tension	% Length	Clearance
Span Sag = 3.57 ft (42.8 in)	(F)	Sag (ft)	(lb)	Change	
Span Tension = 1,789 lb Max Load = 11,200 lb Usable load (60%) = 6,720 lb	-40.0	2.52	2,529	-0.01	N/A
	-30.0	2.59	2,455	-0.01	N/A
	-20.0	2.67	2,382	-0.01	N/A
Catenary Length = 357.095 ft	-10.0	2.76	2,310	-0.01	N/A
Stress Free Length @	.0	2.84	2,240	-0.01	N/A
Installed Temperature = 356.682 ft Unloaded Strand	10.0 20.0 30.0	2.94 3.03 3.13	2,171 2,103	-0.01 -0.01 -0.01	N/A N/A N/A
Sag = 2.14 ft (25.7 in) 0.60 % Tension = 1,525 lb	40.0 50.0	3.23 3.34	2,036 1,971 1,908	0.00 0.00	N/A N/A N/A
	60.0	3.45	1,846	0.00	N/A
	70.0	3.57	1,786	0.00	N/A
	80.0	3.69	1,728	0.00	N/A
	90.0	3.81	1,672	0.00	N/A
	100.0	3.94	1,618	0.01	N/A
	110.0	4.07	1,566	0.01	N/A
	120.0	4.21	1,516	0.01	N/A
	130.0	4.35	1,467	0.01	N/A
	140.0	4.49	1,421	0.02	N/A





NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole

E-2/80 - T-901/53



Project # TID-140 - Primary 7

New Hampshire Optical Systems, Inc.

Proposed **Stream Crossing** Jefferson, NH

The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on

The horizontal distance between the nearest

bridge edge and the existing overhead wires ranges from 75' to 78'. The smallest vertical distance from the top of existing bridge deck to the lowest existing

The vertical distance between the top of

water and bridge deck is approximately 36'.

The waterway is classified as not suitable for

sail boating and per NESC Table 232-1 a vertical clearance of 14' must be maintained between the lowest conductor and 10 year

Based on the FEMA Flood Insurance Rate map 01-16 (Community number 330033C)

Effective April 16, 1986, there is no 10 year, or 100 year, flood event information currently available for this area.

Vertical distances are representative of

moves are completed.

99 Pine Hill Rd.

Notes:

Nashua, NH 03063 (603-821-6467)


Date: 03/23/12


Proposed Stream Crossing Jefferson, NH

<u>Location:</u> Presidential Highway, Jefferson, NH Nearest cross street- Turnpike Rd.

Sheet 2 of 2

K: $\Projects\USNH\dwgs\Jefferson\river_xing\TID-140\TID-140.dwg$







Spanmaster ® Release 3.1 Sag / Tension Computations


		EFF MODULUS	NOMINAL DIAM	EFF.EXP.	CABLE WEIGHT	E*A LOAD BEARING CAPACITY	MAX. RATED LOAD
Selected Cables	(sq.in)	(psi)	(in)	(1/F)	(lb/ft)	(lbs)	(lbs)
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
ORF-O-288-LN Bundle	0.5782	2.70E+05	0.858 1.108	1.13E-05	0.1960 0.3170		651

Waveguide

River and Rail Crossings

	NESC	RES	JLTS						
Wind	Horz Wind	Result Load	Sag	Tension	% Len Chg From	Sag @ Point	Horz Sag	Vert Sag	Vector
Constant lb/ft	Load lb/sq ft	+ Const lb/ft	ft	lb	Input Conditions	83.5 ft	Comp	Comp	Angle Deg
.3	4.0	1.793	3.44	1812	0.09	3.45	1.62	3.04	28.1
.0	0.0	0.317	2.07	535	0.01	2.07	0.00	2.07	0.0

Loading Condition	Temp. (F)	Ice Load lb/ft	Ice Thick in	Wind Constant lb/ft	Horz Wind Load lb/sq ft	Result Load + Const lb/ft	Sag ft	Tension lb	% Len Chg From Input Conditions	Sag @ Point 83,5 ft	Horz Sag Comp ft	Vert Sag Comp ft	Vector Angl Deg	
Rule 251 - Heavy	0.0	1.000	.50	.3	4.0	1.793	3.44	1812	0.09	3.45	1.62	3.04	28.	
232A1	120.0	0.000	.00	.0	0.0	0.317	2.07	535	0.01	2.07	0.00	2.07	0.0	
Span Length : Span Sag = 1			١			Ter (F		Midspa Sag (fi		n % Leng Chang		leara	nce	
Span Tension			,			-40	0.0	1.03	1,072	-0.02		N/A		
Max Loa						-30		1.07	1,029	-0.02		N/A		
Usabl	e load	(60%) =	3,99	0 lb		-20	0.0	1.12	987	-0.01		N/A		
Catenary Len	gth = 1	67.045	ft			-10	0.0	1.17	945	-0.01		N/A		
Stress Free L	ength (@				.()	1.22	905	-0.01	.01 N/A			
Installed T	emper	ature =	166.9	24 ft		10	.0	1.27	866	-0.01		N/A		
						20		1.33	828	-0.01		N/A		
Unloaded Stra						30	.0	1.39	792	-0.01		N/A		
Sag = .87 t		5 in) 0	.52 %			40	.0	1.46	757	-0.01		N/A		
Tension =	484 lb					50	.0	1.53	723	0.00		N/A		
						60	.0	1.60	691	0.00		N/A		
						70	.0	1.67	661	0.00		N/A		
						80	.0	1.75	633	0.00		N/A		
						90	.0	1.82	606	0.01		N/A		
						100	0.0	1.90	580	0.01		N/A		
						110	0.0	1.98	557	0.01		N/A		
						120		2.07	535	0.01		N/A		
						130		2.15	514	0.02		N/A		
						140		2.23	495	0.02		N/A		





NHOS proposes to install a ¼ inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole

E-600/62 - T-164/205



<u>E-600/61 - T-164/206</u>

New Hampshire Optical Systems, Inc. 99 Pine Hill Rd. Nashua, NH 03063 (603-821-6467)

Proposed **River Crossing** Gorham, NH

Notes:

- 1. The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on
- The horizontal distance between the nearest bridge edge and the existing overhead wires is approximately 1' or less.
- Because of the close horizontal proximity to the existing bridge structure, the simplified drawing is submitted with vertical distances measured to the structure. This process simplifies the preparation and review of the crossing without jeopardizing its intent to protect the safe usage of the waterway
- The smallest vertical distance from the top of existing bridge deck to the lowest existing
- The vertical distance between the top of water and bridge deck is approximately 9'.
- Vertical distances are representative of attachment heights after utility make ready

Project # TID-143 - Primary 7

Proposed River Crossing Gorham, NH

Main St., Gorham, NH Nearest cross street- Spruce St

Sheet 2 of 2